

Government of Andhra Pradesh**A.P. State Disaster Response and Fire Services Department****Periodical Renewal Fire Certificate**

From:
Regional Fire Officer
Zone-2,Rajahmundry
Andhra Pradesh.

To:
DEO,

File No: 32188/KKN/RFO/2026, Date:30/05/2026
Occupancy NOC RC Number: 26135/KKN/MSB/2025

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **M/S. BHASHYAM BLOOMS ENGLISH MEDIUM SCHOOL, represented by B RAMAKRISHNA, (BELONGS TO BHASHYAM EDUCATIONAL SOCIETY) NEAR DOOR NO. 1-71, ADB ROAD, ATHAMPETA, PANASAPADU PANCHAYAT, SAMALKOTA MANDAL, KAKINADA DISTRICT. -** Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.
 3. This Office NOC for Occupancy Rc No. 26135/KKN/MSB/2025, Dt.24/04/2025
 4. Renewal NOC For Occupancy 26135/KKN/MSB/2025, Dt.24/04/2025
 5. Online Application for Renewal NOC of B RAMAKRISHNA, (BELONGS TO BHASHYAM EDUCATIONAL SOCIETY) NEAR DOOR NO. 1-71, ADB ROAD, ATCHAMPETA , PANASAPADU PANCHAYAT, SAMALKOTA MANDAL, KAKINADA DISTRICT. - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 29-05-2026.

-- X --

The Management of M/S. BHASHYAM BLOOMS ENGLISH MEDIUM SCHOOL, represented by B RAMAKRISHNA, (BELONGS TO BHASHYAM EDUCATIONAL SOCIETY) NEAR DOOR NO. 1-71, ADB ROAD, ATCHAMPETA, PANASAPADU PANCHAYAT, SAMALKOTA MANDAL, KAKINADA DISTRICT. has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.106050/- vide challan No. 11071882042026, Dated 26/05/2026 at ONLINE, ONLINE.

M/S. BHASHYAM BLOOMS ENGLISH MEDIUM SCHOOL

1. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **B RAMAKRISHNA (BELONGS TO BHASHYAM EDUCATIONAL SOCIETY) NEAR DOOR NO. 1-71, ADB ROAD,ATHAMPETA, PANASAPADU PANCHAYAT, SAMALKOTA MANDAL, KAKINADA DISTRICT.,** subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

4. This Periodical Renewal Fire Certificate is valid from 24/04/2026 to 23/04/2031.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

6. Challan Info:

Challan Number	Challan Date	Challan Amount
11071882042026	2026-05-26	106050

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.

The committee DDRFO & FSI0 - Kakinada inspection remarks are : Recommended : The Management has applied for Renewal of No Objection Certificate and maintaining provided Fire Fighting equipment as per Occupancy NOC. Accordingly, Fire Fighting equipment were tested randomly by the Inspection Committee during the time of inspection on 29.05.2026 and they are in working condition and found satisfactory. Therefore, the Inspection committee is Recommended to issue Renewal of NOC for Occupancy .Hence it is submitted for favor of necessary action Sir.

"Safe School, Safe Hospital & Fire Safety Society-Together for Fire Prevention"


"सुरक्षित विद्यालय, सुरक्षित अस्पताल एवं अग्नि सुरक्षा के प्रति जागरूक समाज आग की रोकथाम के लिए एक साथ"

"సురక్షిత పాఠశాలలు, సురక్షితమైన ఆసుపత్రులు మరియు అగ్నిమాపక భద్రతపై స్పృహ ఉన్న సమాజం మంటలను నివారించడానికి కలిసి పనిచేస్తాయి."

30/5/26



Your Sincerely,


Regional Fire Officer
Zone-2, Rajahmundry
Andhra Pradesh.

In case of emergency, please call 101 or 0884-2374571 or 9963726854

Copy to B RAMAKRISHNA, NEAR DOOR NO. 1-71, ADB ROAD, ATCHAMPETA,
PANASAPADU PANCHAYAT, SAMALKOTA MANDAL, KAKINADA DISTRICT.

Copy to Chief Office for Record Purpose

Copy to District Fire Officer Concerned

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned